

MATERIAL STANDARD**TEST**

This item is a City Light. test document

NOTES:

1. Remove 2-1/2" of thread from one end of a Stock No. 9999.0, 5" rigid steel bushing. I.D. when finished should be 5.575" minimum.
2. Drill and tap 4 holes 1/4"-28. The holes should be 1-1/4" from the unthreaded end and spaced 90 degrees apart.
3. Install 4 each 1/4"-28 x 1/2" hex head cap screws, Stock No. 9999.0.
4. Finish coat:
Coat inside of coupling where threads were removed with Stock No. 9999.0 cold galvanizing.

Stock Unit: EA

Stock No. **9999.0**

ORIGINATOR	STANDARDS COORDINATOR	STANDARDS SUPERVISOR	UNIT DIRECTOR
<i>Jim L. Horn</i>	<i>Charles L. Shaffer</i>	<i>John C. Skinner</i>	<i>Betty Robin</i>